

Landis+Gyr A.E. Corinth, GR-201 00, GREECE

Landis+Gyr E450



T1 T2 T3 T4 R1 R2 PLC

F.F.0 Fehlerregister  
P.1.0 Lastprofil

1.6.0 +Pmax  
2.6.0 -Pmax  
tm=15min

1.8.0/T Energie +A  
2.8.0/T Energie -A  
T = Tarif

3.8.0/T Energie +R  
4.8.0/T Energie -R  
0 = Energie Total

Nr. 40451966




2017




1000

imp/kWh Kl. A  
imp/kvarh Kl. 2

ZMXi3 20 C QU0 L1D3.31 S4  
3x230/400 V 50 Hz 0,25-5(60) A  
PLC: G3-OFDM



OE 17  
E 100



Eigentum des EVUs

netz  
BURGENLAND

30056917 016



T11170  
CE M17 1259  
-40°C...+70°C

G3-PLC