

**STATUS****SYSTEM SETTINGS****SERIAL PORT SETTINGS****COMMUNICATION SETTINGS****ADVANCED SETTINGS****OTHERS**

# Status

System running status overview

## System State


**Product Name**  
PE11**MAC**  
34EAE78D8DC9**DHCP**  
Enable**IP**  
192.168.178.63**Subnet Mask**  
255.255.255.0**Gateway**  
192.168.178.1**DNS**  
223.5.5.5**Firmware Version**  
1.34.13**System Time**  
NTP Disabled**Total Running Time**  
0-Day 0:4:22**Remaining RAM**  
21740**Max Block Size**  
17984**Configuration Protected**  
Disable


## Serial Port State


**Received Bytes**  
3600**Received Frames**  
400**Sent Bytes**  
3200**Sent Frames**  
400**Failed Bytes**  
0**Failed Frames**  
0**Config**  
9600,8,1,NONE


## Communication State - 'netp'


**Received Bytes**  
4800**Received Frames**  
400**Sent Bytes**  
5200**Sent Frames**  
400**Failed Bytes**  
0**Failed Frames**  
0**Protocol**  
TCP-SERVER**State**  
Server Created**IP**


 STATUS

 SYSTEM SETTINGS

 SERIAL PORT SETTINGS

 COMMUNICATION SETTINGS

 ADVANCED SETTINGS

 OTHERS


# System Settings

Change the device system settings

Authentication



User Name

admin



Password

•••••



Basic Settings

Host Name

Eport-PE11

WAN Settings

DHCP

ON

DNS

223.5.5.5


Telnet Settings

Enable

ON

Telnet Port

23



Echo

ON


Web Settings

Enable

ON

Web Port

80




NTP Settings


Enable


OFF


Submit


Reset


 STATUS

 SYSTEM SETTINGS

 SERIAL PORT SETTINGS

 COMMUNICATION SETTINGS

 ADVANCED SETTINGS

 OTHERS

# Serial Port Settings

change the device serial port settings

Basic Settings

Baud Rate

9600

▼

Data Bit

8

▼

Stop Bit

1

▼

Parity

None

▼

Buffer Settings

Buffer Size

512

⬆⬇⬆

Gap Time

50

⬆⬇⬆

Flow Control Settings

Flow Control

Disable

▼

Cli Settings

Cli

Serial String

▼

Serial String

+++

Waiting Time

300

⬆⬇⬆

Protocol Settings


Protocol


Modbus


▼


Submit


Reset


 STATUS

 SYSTEM SETTINGS

 SERIAL PORT SETTINGS

 COMMUNICATION SETTINGS

 ADVANCED SETTINGS

 OTHERS

# Communication Settings


change the device socket settings

netp+Add

Basic Settings

Name

netp



Protocol


Tcp Server

▼

Socket Settings


Local Port

8899




Buffer Size

512




Keep Alive(s)

60



Timeout(s)


0



Protocol Settings

Max Accept

3



More Settings

Security

Disable

▼

Route

Uart

▼

Submit

Delete

Reset